Oil Tanks



The Tuffa range of oil storage tanks is well-regarded in the industry and has been trusted by businesses, homes, and farms for their heating needs for more than 30 years.

Bunded Oil Tanks / Plastic







Capacity	Length	Width	Height	Weight
1,350 litres	2,680mm	870mm	1,665mm	170kg



1400VB

Capacity			_
1,400 litres	1,585mm	1,750mm	120kg



2500HB

Capacity	Length	Width	Height	Weight
2,500 litres	2,840mm	1520mm	1,630mm	260kg

Bunded Oil Tanks / Steel



1000SB (1)



Capacity	Length	Width	Height	Weight
1,000 litres	1,800mm	600mm	1,680mm	320kg











1650SB 4



Capacity				
1,670 litres	1,800mm	900mm	1,680mm	380kg












2300SB













3500VB

Capacity	Diameter	Height	Weight
3,500 litres	2,013mm	2,520mm	280kg



6000VB

Capacity	Diameter	Height	Weight
6,000 litres	2,550mm	2,585mm	360kg



10000VB

Capacity	Diameter	Height	Weight
10,000 litres	2,890mm	2,590mm	430kg



15000VB

Capacity Diameter 15,000 litres 2,890mm		Height	Weight	
15,000 litres	2,890mm	3,500mm	630kg	

Cabinet dimensions (3500+ models):

Height	Width	Depth	Weight
2,000mm	1,200mm	600mm	50kg






For when space is restricted and for easier movement

Faster Installs

Our steel tank models have been designed to accommodate pre-fabricated concrete bases, for faster installs and cheaper costs.





Fire Rated Oil Tanks



FirePro $^{\circ}$ is a tier-one bunded oil tank that's integrally fitted with a unique, patented fire jacket providing 30 or 60-minute fire protection.



The unique product provides compliant installation as close as 300mm from the walls or boundaries and can even be installed inside domestic outbuildings.

Fire Protected Oil Tanks / Plastic

1350SLBFP 🕕

Capacity	Length	Width	Height	We 30min	
1,150 litres	2,680mm	870mm	1,665mm	195kg	238kg



1400VBFP

Capacity	Diameter	Height We		
1,200 litres	1,585mm	1,750mm	140kg	171kg



2500HBFP

Capacity			Height	We 30min	60min
2,440 litres	2,840mm	1,520mm	1,630mm	290kg	337kg











Fire Protected Oil Tanks / Steel









Who can sign-off and certify a fire rated tank?

A Tuffa FirePro installation requires an independent sign-off to comply with building regulations. Failure to do so would render an installation incompliant.

There are three options:

- 1. Stroma approved persons inspection.
- 2. Self-certification through a competent person scheme.
- 3. Certification via a building notice by local authority building control.

Find out more about the ease of signing off a Tuffa fire-rated oil tank by visiting www.tuffa.co.uk/buyers-guides/guide-to-firepro-sign-off









